

Объект:
Адрес: Социалистическая 48
источник теплоты: ТЭЦ ОАО "Бийскэнерго"

Идентификационный номер прибора: ИД=08220
Схема потребления: СП=0

Сутки, час		Время счета Ти	подающий труб.			обратный труб.			M3	V3	Тепло Q прибор
			t1	V1	M1	t2	V2	M2			
21.12.21	23:00	24.00	67.57	103.967	101.823	45.32	96.632	95.691	6.132	6.261	2.546
22.12.21	23:00	24.00	71.99	104.798	102.372	47.36	97.166	96.134	6.237	6.385	2.820
23.12.21	23:00	24.00	77.29	105.190	102.423	49.79	97.217	96.080	6.343	6.514	3.137
24.12.21	23:00	24.00	76.97	104.799	102.063	49.78	97.433	96.294	5.769	5.923	3.067
25.12.21	23:00	24.00	75.14	104.403	101.793	49.06	96.877	95.776	6.017	6.171	2.954
26.12.21	23:00	24.00	75.70	104.208	101.568	48.89	95.106	94.032	7.535	7.731	3.095
27.12.21	23:00	24.00	75.76	103.498	100.872	48.81	95.537	94.462	6.410	6.577	3.036
28.12.21	23:00	24.00	75.46	105.506	102.848	48.83	97.454	96.357	6.492	6.659	3.060
29.12.21	23:00	24.00	78.70	104.201	101.370	49.74	95.794	94.676	6.694	6.881	3.273
30.12.21	23:00	24.00	85.90	104.877	101.548	52.74	95.140	93.898	7.650	7.901	3.777
31.12.21	23:00	24.00	86.96	107.106	103.634	52.98	95.498	94.241	9.393	9.707	4.026
01.01.22	23:00	24.00	87.12	105.997	102.549	53.37	97.718	96.414	6.135	6.342	3.796
02.01.22	23:00	24.00	86.58	105.293	101.906	52.76	96.742	95.478	6.427	6.641	3.792
03.01.22	23:00	24.00	86.06	104.760	101.425	53.12	97.167	95.881	5.543	5.726	3.642
04.01.22	23:00	24.00	79.32	105.740	102.826	50.64	97.197	96.023	6.804	6.996	3.298
05.01.22	23:00	24.00	77.39	106.612	103.802	49.97	97.606	96.457	7.345	7.544	3.217
06.01.22	23:00	24.00	79.85	106.251	103.288	51.03	97.823	96.624	6.664	6.855	3.322
07.01.22	23:00	24.00	81.67	105.660	102.594	51.62	97.538	96.316	6.278	6.466	3.413
08.01.22	23:00	24.00	82.23	106.546	103.417	52.35	98.845	97.573	5.844	6.021	3.401
09.01.22	23:00	24.00	80.52	107.250	104.216	51.85	98.521	97.276	6.939	7.141	3.353
10.01.22	23:00	24.00	82.34	106.218	103.090	52.47	98.508	97.235	5.856	6.033	3.392
11.01.22	23:00	24.00	87.24	108.202	104.674	54.79	99.803	98.403	6.271	6.482	3.747
12.01.22	23:00	24.00	88.00	107.716	104.150	54.90	98.982	97.588	6.561	6.786	3.815
13.01.22	23:00	24.00	87.83	106.505	102.991	54.53	97.881	96.520	6.471	6.691	3.790
14.01.22	23:00	24.00	87.09	104.717	101.313	53.72	96.240	94.939	6.374	6.588	3.729
15.01.22	23:00	24.00	81.21	105.145	102.124	51.23	96.350	95.160	6.964	7.170	3.423
16.01.22	23:00	24.00	73.87	104.868	102.325	48.27	95.506	94.454	7.871	8.067	3.003
17.01.22	23:00	24.00	75.74	105.240	102.568	49.71	97.713	96.574	5.995	6.151	2.972
18.01.22	23:00	24.00	77.57	104.314	101.551	50.37	97.218	96.055	5.496	5.645	3.042
19.01.22	23:00	24.00	82.19	104.645	101.574	52.39	97.319	96.065	5.509	5.675	3.321
20.01.22	23:00	24.00	89.90	105.112	101.498	55.30	96.819	95.437	6.061	6.277	3.854
ИТОГО		744.00	80.68	3269.34	3176.19	51.22	3011.35	2974.12	202.07	208.00	104.113
		ч	°C	МЗ	Т	°C	МЗ	Т	Т	МЗ	Гкал

P1k = 5,5 кг/см2, P2k = 4 кг/см2
температура холодной воды (константа прибора) 0 °C
температура холодной воды за отчетный период 0,2 °C

Дата: 21 Январь 2022

Исполнитель: _____ / Букач В.В. /

Представитель ОАО "БийскэнергоТеплоТранзит": _____ /

